

CLINTON CONCRETE PRODUCTS, LLC
WILLIAM DELONG
305 SCOT DRIVE DR
CLINTON WI 53525

September 16, 2002

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: CLINTON CONCRETE PRODUCTS, LLC
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR OR PUMP
Model Number(s): 1000
(43.5" L.L., 23.06 GAL/IN., 96" MAX. DEPTH OF BURY, 480 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20020321

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2007.

This approval is contingent upon compliance with the following stipulation(s):

- The products produced by this manufacturer are approved to use the following:
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Optional discharge opening from riser.
 - Three inch schedule 40 PVC cast in riser for electrical wiring and/or force main.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L, TSS of greater than 30 mg/L or less than or equal to 150 mg/L TSS and F.O.G. of less than 30 mg/L.

This approval supercedes the approval issued on July 21, 2000 under product file number 20000592.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000592.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Phone (608) 261-0450